



Open Path Infrared Gas Detector

zellweger analytics

SEARCHLINE EXCEL CALIBRATION CERTIFICATE

DATE 30.01.2009

MODEL NUMBER 2104B2111

SYSTEM TYPE
S/R M/R L/R D/M

SERIAL NUMBER 01/09/088

CALIBRATION GAS (see note 1) Methane

FILTER TYPE
STANDARD ETHYLENE DUCT MOUNT

PLASTIC FILTER INFORMATION

Low Alarm	High Alarm
Filter Letter = <u>D</u>	Filter Letter = <u>F</u>
Gas Reading = <u>0.95</u>	Gas Reading = <u>2.40</u>

TECHNICIAN / ENGINEER [Signature] EMPLOYEE No. 102

Notes:
1. This unit has been factory calibrated, and does not require further calibration. Please see operating instructions for additional details.

ZELLWEGER ANALYTICS Ltd. 4 Stinsford Road, Poole, BH17 0RZ. 2104D0200_2/A02379.xls



Description: Sieger, Searchline Excel, Open Path Infrared Gas Detector

External ID: 2695076

Category: Instrumentation

Subcategory: Fire and Gas Detection

Manufacturer: Zellweger Analytics Ltd

Model: —

Serial No: 01/09/088

Part No: 2104B2111

Year: —

Weight [kg]: 9,5

Dimension (L x B x H) [m]: 0,43X0,31X0,13

Condition: New

Tag No: —



URL:

<https://www.modernamericanrecyclingservices.com/equipment/open-path-infrared-gas-detector-2695076/>

Frederikshavn, Denmark

European Large Scale Recycling

Sandholm 55H
9900 Frederikshavn

+45 53365179
kim@mars-eu.dk